


STRUCTURE TEST

JUNE 21, 1984



**KANSAS CITY POWER & LIGHT COMPANY
KANSAS CITY, MISSOURI
HUGHES TYPE C4523-A TANGENT STRUCTURE
345 KV CONSTRUCTION**

HUGHES
BROTHERS
Seward, Nebraska

HUGHES BROTHERS

P.O. BOX 159 • 210 NORTH 13TH STREET • SEWARD, NEBRASKA 68434 • PHONE (402) 643-2991 • TELEX 438076

PURPOSE:

The purpose of these tests was to confirm design calculations and the structural capability of the Hughes Type C4523-A H-frame tangent structure for various loading conditions.

PROCEDURE:

Two structures were framed and erected for these tests. The structure top, from the X-brace up, was framed on short pole stubs. A complete structure was framed on 85 ft. Class I Douglas Fir poles. The actual pole dimensions are listed in the body of the report.

The pole top structure was loaded in the vertical direction to the maximum design load times an overload capacity factor of 4.0. The loading was accomplished by means of hydraulic cylinders and known dead weights. The three phase positions were loaded equally and simultaneously.

The pole top structure was then loaded transversely by means of power winches. The loads were monitored by dynamometers and transverse deflection readings taken.

A premature failure of a 7/8 x 12" drop-forged turnbuckle in the west tension brace caused a short delay. The turnbuckle was replaced with an identical unit and the structure loaded to maximum design load requirements.

The full size structure was initially loaded vertically to NESC light loading conditions times an overload capacity factor of 4.0. The structure was then loaded incrementally in the transverse direction to failure. The transverse loads were applied by power winches and monitored with dynamometers.

DISCUSSION:

Investigation of the failed turnbuckle did not produce any positive reasons for the premature failure. The steel analysis appeared to be normal. The turnbuckle was manufactured by a very reputable and dependable company. Their quality control people are continuing the investigation.

HUGHES BROTHERS


P.O. BOX 159 • 210 NORTH 13TH STREET • SEWARD, NEBRASKA 68434 • PHONE (402) 643-2991 • TELEX 438076

CONCLUSION:

The Hughes Type C4523-A structure performed favorably. All design criteria was met. Strengthening of the spacer fittings was deemed necessary by the Hughes Brothers, Inc. engineering staff and has been accomplished.

Respectfully submitted,

HUGHES BROTHERS, INC.



Stephen F. Smith
Vice-President, Engineering


SFS:jap

TYPE C4523-A, 34.5KV TANGENT STR.
 KANSAS CITY POWER & LIGHT CO.
 FULL SIZE STRUCTURE TEST

NEESC LIGHT

TEST No. 2

VERTICAL LOADS
 East Phase 10,450 lbs.
 Center Phase 10,450 lbs.
 West Phase 10,450 lbs.
 Per Shield Wire 1,200 lbs.



TRANSVERSE LOADS


SHIELD WIRE (EA)	COND (EA)	TOTAL LOAD	DEFLECTIONS (IN.)												PIC. No.	
			WEST POLE			EAST POLE			THRUST	LOADS			LIFT			
			A	B	C	A	B	C		A	B	C				
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	T2P1
0	0	0	VERTICAL			LOADS			APPLIED						T2P2	
300	1,850	6,150	3 3/4	3 1/8	2	1 5/8	1/4	2 5/8	3 1/8	2 3/8	1 3/8	0	0	0	0	T2P3
600	3,700	12,300	7 3/8	6 3/8	4 5/8	3 1/2	1/2	6 3/4	6 3/4	5	3 3/8	1/8	1/8	1/8	1/8	T2P4
900	5,550	18,450	14 3/4	12 3/8	9 1/8	6 3/4	3/4	12 3/4	12	8 1/8	5 1/8	5 1/8	1/4	1/4	1/4	T2P5
1,200	7,400	24,600	24 3/8	20 3/8	15 3/4	10 3/4	1 1/8	23	20 3/4	15 3/4	10	10	1/4	1/4	1/4	T2P6
1,500	8,325	27,675	34 3/8	29 3/8	22 1/2	15	1 1/4	31 1/2	28 3/8	22 1/4	14 1/2	14 1/2				T2P7
1,500	9,250	30,750	FAILURE			FAILURE			FAILURE			FAILURE				T2P8

* Vertical loads applied during entire test represent NEESC LIGHT loading x an overload capacity factor of 4.0.

Drawn *J. Mifflin*
 Approved



Date Printed
 DRG. NO. A2345-C




Test No. 2
Photo No. 7

Vertical Loads

per shield wire = 1,200 lbs.
per phase = 10,450 lbs.

Transverse Loads

per shield wire = 1,350 lbs.
per phase = 8,325 lbs.
Total = 27,675 lbs.



Test No. 2
Photo No. 8

Failure


Vertical Loads

per shield wire = 1,200 lbs.
per phase = 10,450 lbs.

Transverse Loads

per shield wire = 1,500 lbs.
per phase = 9,250 lbs.
Total = 30,750

HUGHES
BROTHERS



3A08 Adj. Spacer
Fitting Or 3A523-4
Fixed Spacers
13'6"

See Dr'g. C4523-41
Detail 'A'

C4523.14 Arm With Adj. Spacers- HS-10A
Or C4523.34 With Fixed Spacers- HS-10F
5/8" x 7/8" Laminated
Double Arm

NOTE: Bonding Wire Or Cross Arms To
Be Field Assembled (by others)

9" x 7 Strand
EHS Galvanized Strand

1'6" x 1'6"

AS2345-C 3/8" x 12" Jaw
Jaw Turnbuckle

3/8" Bolt, Lock Nut,
Eccentric Spring
Washer (2702) Bonding
Clip (222781)


283578-6384, Shield
Wire Support

28082 Roller
28578-60
28578-60
28578-60

MIF PRX 2618 Grid
Gain

1'6"

10'9" ±



AS2222-8 Pole Washer
AS2217 Gears, 28092
Roller, 3/8" Bolt, Lock Nut

1/2" x 7 Strand EHS Galvanized Steel Strand

AG2115 Guy G-1P

C4523.24
1/2" x 3/4" (58 x 7/8)

3/4" Thrd Rod 2-MIF PRX 2618
Grid Gain, 2-2702, 8 Spring
Washer, 1-2712, 8 Bonding
Clip, 3-Nuts (N80), 3-Clips (833) Round
Washer, 2-Locknuts (N80)

See Arm Mounting Detail
on C4523-41

MIF PRX 26082 Grid Gain

28082
Grid Gain
1x 1/2" Bolt, Lock Nut

TYPE HS-10A or HS-10F TANGENT STRUCTURE
345 KW CONSTRUCTION

KAUSAS CITY POWER PLANT CO.
KAUSAS CITY, MISSOURI

KAUSAS CITY POWER PLANT CO.
 KAUSAS CITY, MISSOURI

DRG. C4523-4